

Art. Nr. / Ref-No.:
IPR 300 SREG



[Changelog – Versionshistorie](#)



[Change log - Version history](#)

KNX IP- Router

Art.-Nr.: [IPR 300 SREG](#)

Versionen der Gerätefirmware und der Applikationen:



Was gibt es Neues?

Firmware-Version 1.056:

- Verwende deinen IP-Router als **Zeitgeber** für das KNX System um die Uhrzeit stets aktuell zu halten
- Verwende deinen IP-Router als Tor (**Mapper**) zwischen einer sicheren und herkömmlichen Gruppenadresse
- Erweitere Kompatibilität mit DHCP Servern

Ausgelieferte Geräte können aus dem [JUNG Onlinekatalog](#) mit der neuen Firmware aktualisiert werden. Das Software-Update kostenfrei.


KNX IP-Router


Art.-Nr.: [IPR 300 SREG](#)

Versionen der Gerätefirmware und der Applikationen:

KNX Produktdatenbank	Kompatible Firmware	Beschreibung
All_IPX300SREG_20200729.knxprod	Kompatibel ab Firmware 1.056	Zusatzapplikation für Zeitserver / Mapper
All_IPX300SREG_20191119.knxprod	Kompatibel ab Firmware 1.028	Anpassung der Produktbeschreibung und Übersetzung
All_IPX300SREG_20190801.knxprod		



Die aktuelle Firmware der Geräte kann am Gerät selbst, über Telnet (z.B. Putty) oder das [Konfigurationstool](#) ausgelesen werden.


KNX IP Router IPR 300 SREG:				
Datum	Geräte-ID	Firmware	Beschreibung	ETS
29.06.2020	V05	1.056 	<ul style="list-style-type: none"> - Zeitgeber und Mapper über Zusatzapplikation (IPR300SREG) möglich - Kompatibilität der vergebenen IP-Einstellungen (DHCP-Refresh) bei spezifischen DHCP Servern erweitert - Änderung der KNX Anschlussklemme 	All_IPX300SREG_20200629

INFO:  = Master Reset wird automatisch ausgeführt

* AN158v06, AN193, AN194

KNX IP Router
IPR 300 SREG:

Datum	Geräte-ID	Firmware	Beschreibung	ETS
27.06.2020	V04	1.039 	- Änderung der Beschriftung des Gehäuseoberteils	All_IPX300SREG _20191119
13.01.2020	V03		- Verbesserung beim Systemstart mit stark erhöhter Buslast - Verbesserung beim Update von KNX Secure Geräten	
08.10.2019	V02	1.035 	- Verfahrensänderung zum Masterreset - Power LED leuchtet im Betrieb dauerhaft - Implementierung des neusten KNX Secure Standards*	All_IPX300SREG _20191119
01.08.2019	V00	1.028	- Initiale Auslieferung	

INFO:  = Master Reset wird automatisch ausgeführt

* AN158v06, AN193, AN194

KNX IP- Router

Ref. No.: [IPR 300 SREG](#)

Versions of device firmware and applications:



What's new?

Firmware-Version 1.056:

- Use your IP router as a **timer** for the KNX system to keep the time up to date
- Use your IP router as a tor (**mapper**) between a secure and traditional group address
- Erweitere Kompatibilität mit DHCP Servern

Delivered devices can be updated with the new firmware from the [JUNG online catalogue](#).
As usual, the software update is free of charge.


KNX IP-Router


Ref. No.: [IPR 300 SREG](#)

Versions of device firmware and applications:

KNX Data base	Compatible Firmware	Description
All_IPX300SREG_20200629.knxprod	Compatible Firmware 1.056	Additional application for Time server / mapper
All_IPX300SREG_20191119.knxprod	Compatible Firmware 1.028	Adaptation of the product description and translation
All_IPX300SREG_20190801.knxprod		



The current firmware of the devices can be read out one the device itself, via Telnet (eg Putty) or the [configuration tool](#).


KNX IP Router IPR 300 SREG:				
Date	Label	Firmware	Description	ETS
29.06.2020	V05	1.056 	<ul style="list-style-type: none"> - timer and mapper possible via additional application - Enhanced compatibility of assigned IP settings (DHCP refresh) for specific DHCP servers - Modifying the KNX Bus conection block 	All_IPX300SREG _20200629

INFO:  = Master Reset is performed automatically

* AN158v06, AN193, AN194

KNX IP Router
IPR 300 SREG:

Date	Label	Firmware	Description	ETS
27.06.2020	V04	1.039 	- Changing the labelling of the upper part of the device	AIL_IPX300SREG_20191119
13.01.2020	V03		- Improvement during system startup with highly increased bus load - Improvement when updating KNX Secure devices	
08.10.2019	V02	1.035 	- Change of procedure to master reset - Power LED lights up continuously during operation - Implementing latest Security Update for KNX Secure*	AIL_IPX300SREG_20191119 9
01.08.2019	V00	1.028	- Initial release	AIL_IPX300SREG_20191119

INFO:  = Master Reset is performed automatically

* AN158v06, AN193, AN194