


Datasheet RCUXXYY

EAE KNX Room Control Unit

All you need is EAE




www.eaetechnology.com



Datasheet RCUXXYY

EAE KNX Room Control Unit

General Description



Available versions of EAE RCU Series:

RCU1212	12 Output – 12 Input	48130
RCU1200	12 Output – No Input	48129
RCU0808	8 Output – 8 Input	48128
RCU0800	8 Output – No Input	48127

Note: RCUXXYY where XX denotes the number of outputs and YY number of inputs.

- Room Control Unit has multiple 16A relay outputs. These
 outputs are grouped as 5/4/3/2 independent output
 channel groups for XX = 20/16/12/8 respectively. Each
 channel group can be configured to have different modes
 of operation as follows;
 - Switching output x4
 - AC Blind x2
 - DC Blind x1
 - On/Off (2-point) valve x2
 - 3-point valve x2
- Room Control Unit has optional multiple independent input channels. Each input is galvanically isolated. Input channels operate as universal interface to KNX bus with following functions;
 - Switch / push button input
 - Dimmer control
 - Control of shutter/blinds
 - Value sending
 - Scene control
 - Counter for count pulse

- Room Control Unit RCU Series are designed as an all in one product for different room layouts such as apartments, hotel rooms, hospitals and residences.
- Room Control Unit covers all requirements of the electrical installation of room applications and offers following functions in a one product.
 - Switching lighting control
 - Switching load control
 - Controlling AC/DC blinds
 - Controlling fan coils (On/Off & 3-point valve)
 - Dry contact inputs
- Suitable for switching resistive, capacitive and inductive loads as well as fluorescent lamp loads according to EN 60 669. As a switch output device provides following function list,
 - Staircase
 - External logic
 - Internal logic
 - Priority
 - Threshold
 - Operating hour
 - Sweep
- Manual control is possible for each channel through the built-in button panel.
- 220V auxiliary power is NOT required.



Datasheet RCUXXYY EAE KNX Room Control Unit


Technical Data RCU Series

Type of protection	IP 20	EN 60 529		
Safety class	II	EN 61 140		
•				
Power supply :	- Voltage	21V 30V DC, SELV		
	- Current consumption	≤ 10 mA		
External supply	-	-		
Connections	- Screw terminals	0,53,31 mm ² solid and stranded wire 0,53,31 mm ² stranded wire with ferrule 0.5 Nm		
	- Max tightening torque			
	- KNX	Bus connect terminal		
Output	- Number	XX output		
	- Switching voltage	250 V AC; 50/60 Hz		
	 Switching current 250 V AC Switching current 250 V AC, capacitive loads 	16A / AC 1 16A (200μF)		
	- Maximum switching power	4000 VA		
	- Mechanical life	> 1 x 106		
Type of load	- Incandescent lamp	4000 W		
	- Halogen lamp	4000 W		
	- Inductive loads, transformer	2000 W		
	- Electronic drivers	1500 W		
Type of contact	- Potential-free, bistable, isolated			
Input	- Number	YY binary inputs		
	- Scanning voltage	5 V		
	- Current	1 mA		
	- Cable length	< 300 m		
Installation	- 35mm mounting rail	EN 60 715		
Operating elements	- LED (red) and button	For physical address		
Temperature range	- Ambient	-5° C + 45° C		
	- Storage	-25° C + 55° C		
Humidity	- max. air humidity	85 % no moisture condensation		
Dimensions	Width W in mm Width W in units (18 mm modules)	90 x W x 90mm 108 mm 6 units		
Weight	0,65 kg			
Вох	Plastic, polycarbonate, colour grey			
CE	In accordance with the EMC guideline and low voltage			
Application program	Communications objects	Number of addresses(max)	Number of assignments(max)	
	254	255	255	



Datasheet RCUXXYY EAE KNX Room Control Unit

Grouping Topology Visual



	Lighting	AC Blind	DC Blind	Fan Coil Fan Control	Valve Control
RCU12YY	A1A2-B1B2 F1F2	A-B-C-D-E-F	AB – CD – EF	AB – CD – EF	AB – CD – EF
RCU08YY	A1A2-B1B2 D1D2	A-B-C-D	AB – CD	AB – CD	AB – CD

For lighting and AC Blinds;

• Channels can be used individually, in example: A1 & A2 can be used as a switch for lighting and B1 & B2 can be used as an AC Blind etc. as shown with **red coloured** drawings in above visual

For DC Blind, Fan Coil Fan Control and Valve Control;

 Subsequent channels are linked together, in example: G1G2 and H1H2 have to be used together for DC Blind etc. as shown with blue coloured drawings in above visual



Datasheet RCUXXYY

EAE KNX Room Control Unit

Scale Dimensions RCUXXYY

