



KNX S1R-B4-UP 24 V

Actuator for a 12/24 V DC motor

Technical specifications and installation instructions

Item number 70206



Elsner Elektronik GmbH Control and Automation Engineering

Sohlengrund 16
75395 Ostelsheim
Germany

Phone +49 (0) 70 33 / 30 945-0 info@elsner-elektronik.de
Fax +49 (0) 70 33 / 30 945-20 www.elsner-elektronik.de

Technical support: +49 (0) 70 33 / 30 945-250

1. Description

The **Actuator KNX S1R-B4-UP 24 V** with integrated façade controller regulates the 12 or 24 V DC motor for a shutter, an awning, a blind or window. Because the output is designed to be potential-free, other systems can also be controlled, e.g. via the manual switch input on a motor control unit.

Automation is specified externally or internally. Internally, there are numerous options available for blocking, locking (e.g. master-slave) and priority definitions (e.g. manual-automatic). Scenes are saved and called up via the bus (scene control with 16 scenes per drive).

The **KNX S1R-B4-UP 24 V** has four inputs that are used as binary inputs (switches, alarm messages etc.) or as analogue inputs for T-NTC temperature sensors.

Functions:

- **Potential-free output** with polarity changer for a **12 V DC or 24 V DC drive** (shade, window)
- **4 inputs** for binary contacts or temperature sensor
- **Automatic runtime measurement** of the drives for positioning (incl. fault reporting object)
- Position feedback (movement position, also slat position for shutters)
- Position storage (movement position) via 1-bit object (storage and call-up e.g. via buttons)
- Parameters for taking drive and mechanics downtimes into account
- Control via **internal or external automation functions**
- Integrated **shade control** with **slat tracking** according to sun position for shutters
- **Scene control** for movement position with 16 scenes per drive (also slat position for shutters)
- Mutual **locking** of two drives using zero position sensors prevents collisions e.g. of shade and window (master-slave)
- Blocking objects and alarm reports have different priorities, so safety functions always take precedence (e.g. wind block)
- Manual or automatic priority setting via time or communication object
- **4 temperature switching outputs** in the application program with adjustable threshold values (presetting the parameters or communication object)
- **4 AND and 4 OR logic gates** each with 4 inputs. 16 logic inputs (in the form of communication objects) are available as inputs for the logic gates. The output from each gate can be configured optionally as 1-bit or 2 x 8-bit

Configuration is made using the KNX software ETS. The **product file** can be downloaded from the Elsner Elektronik website on **www.elsner-elektronik.de** in the "Service" menu.

1.0.1. Scope of delivery

- Actuator

1.1. Technical specification

Housing	Plastic
Colour	White
Assembly	Flush mounting (in junction box \varnothing 60 mm, 60 mm deep)
Protection category	IP 20
Dimensions	approx. 50 x 50 x 54 (W x H x D, mm)
Weight	approx. 100 g
Ambient temperature	Operation -20...+70°C, storage -30...+85°C
Ambient humidity	5...80% RH, non-condensing
Operating voltage	KNX bus voltage
Power	on bus: 10 mA at 12/24 V DC: typically 5 mA, max. 10 mA
Output	1 x Potential-free output with polarity changer for 12/24 V DC drive Up/Down (+/-/motor). Load capacity: max. 5 A with resistive load Starting current: max. 5 A
Minimum current for run-time measurement	DC effective 100 mA
Inputs	4x analogue/ digital, max. cable length 10 m.
Setting range for the T-NTC temperature sensor at the input	-30°C...+80°C
Data output	KNX +/- bus plug-in terminals
BCU type	Integrated microcontroller
PEI type	0
Group addresses	max. 1024
Assignments	max. 1024
Communication objects	239

The product is compliant with the provisions of EU guidelines.

2. Installation and commissioning

2.1. Installation notes



Installation, testing, operational start-up and troubleshooting should only be performed by an electrician.



CAUTION! **Live voltage!**

There are unprotected live components inside the device.

- National legal regulations are to be followed.

- Ensure that all lines to be assembled are free of voltage and take precautions against accidental switching on.
- Do not use the device if it is damaged.
- Take the device or system out of service and secure it against unintentional use, if it can be assumed, that risk-free operation is no longer guaranteed.

The device is only to be used for its intended purpose. Any improper modification or failure to follow the operating instructions voids any and all warranty and guarantee claims.

After unpacking the device, check it immediately for possible mechanical damage. If it has been damaged in transport, inform the supplier immediately.

The device may only be used as a fixed-site installation; that means only when assembled and after conclusion of all installation and operational start-up tasks and only in the surroundings designated for it.

Elsner Elektronik is not liable for any changes in norms and standards which may occur after publication of these operating instructions.

2.2. Installation




Fig. 1: Bus side

- 1 Connector analogue/digital inputs
- 2 Label field
- 3 KNX plug terminal +/-
- 4 Programming LED and programming button (countersunk)

Analogue/digital inputs connector assignment:

1: GND | 2: IN1 | 3: GND | 4: IN2 | 5: GND | 6: IN3 | 7: GND | 8: IN4

All GND connectors are internally bridged.




Fig. 2: Output side

1 Connector for 12 V DC or 24 V DC motor
(free of potential)

2.3. Connection

The **Actuator KNX S1R-B4-UP 24 V** is installed in a flush-mounted socket. The connection is made using a KNX connector on the KNX data bus. In addition, a power supply for the connected drive is necessary (potential-free output).



Follow the guidelines and standards for SELV electric circuits while installing and cable laying of the KNX connection and inputs!



ATTENTION!

When first switched on, relays may be live!

The bistable relays used in this product can switch themselves on when subjected to strong vibration, e.g. during transport.

- First of all connect the bus voltage; this will switch off the relays. Only then can the power supply for the drive be switched on.

The physical address is assigned by the KNX software. There is a button with a control LED for this on the actuator.

2.3.1. Connection examples

Output:




Fig. 3
Example for the connection of a 24 V DC motor.

Inputs:




Fig. 4
Example KNX S1R-B4-UP with binary contact on input 1 and T-NTC temperature sensor on input 4.

Connection of the temperature sensor is independent of the polarity.

2.4. Instructions for assembly and initial start-up

Never expose the actuator to water (e.g. rain) or dust. This can damage the electronics. You must not exceed a relative air humidity of 80%. Avoid condensation.

After the auxiliary voltage has been applied, the device will enter an initialisation phase lasting a few seconds. During this phase no information can be received or sent via the bus.

For KNX devices with safety functions (e.g. wind or rain blocks), it is important to set up periodical monitoring of the safety objects. The ideal ratio is 1:3 (example: if the weather station sends a value every 5 minutes, the actuator must be configured for a monitoring period of 15 minutes).

3. Addressing of the device at the bus

The device is supplied with the bus address 15.15.250. You can program another address into the ETS by overwriting the 15.15.250 address or by teaching via the programming key.