

1.3 Device generations and using the application programs

There are different application programs available. The use of the newer application programs together with the current device generation results in functional differences as compared with the combination of older applications and devices. It is possible to distinguish between the application programs and device generations by means of the application number and release designation (see the following table):

Release designation	Application number	Compatibility	Possible functions at the input
V02	706811	compatible	- Pulse counter (new) - Switching - Dimming - Blind - Value transmitter
V02	706311	compatible	- Switching - Dimming - Blind - Value transmitter
V01	706811	incompatible	No operability!
V01	706311	compatible	- Switching - Dimming - Blind - Value transmitter
R0	706811	incompatible	No operability!
R0	706311	compatible	- Switching - Dimming - Blind - Value transmitter

The release designation of the device generation is attached on the device label.(figure 1).

- i** Devices with release designation "R0" or "V01" can not be used for project design or be set into operation with application program 706811.
- i** Devices with release designation "V02" or later can also be set into operation with application program 706311 by using the ETS3.0d with Patch A or newer versions of the ETS. Application program 706311 does not have a pulse counter function.