

---

04/2012

# Technical Manual

## MDT Universal Interfaces



BE – 02001.01

BE – 04001.01

## 1 Content

1 Content.....	2
2 Overview.....	4
2.1 Overview devices.....	4
2.2 Exemplary circuit diagrams .....	4
2.2 Usage & areas of use .....	6
2.4 Structure & Handling.....	6
2.5 Functions .....	7
2.5.1 Overview functions.....	8
2.6 Settings at the ETS-Software .....	9
2.7 Starting up .....	9
3 Communication objects .....	10
3.1 Communication objects per channel .....	10
3.2 Communication objects logic .....	12
3.3 Default settings of the communication objects .....	13
4 Reference ETS-Parameter .....	14
4.1 General Settings .....	14
4.2 Configuration .....	16
4.3 Identical parameter .....	17
4.3.1 Blocking object .....	17
4.4 Parameter Channels grouped.....	17
4.4.1 Dimming .....	18
4.4.2 Shutter .....	20
4.4.3 Switch .....	21
4.5 Parameters channels unique.....	22
4.5.1 Switch .....	22
4.5.2 Scene .....	32
4.5.3 Counter .....	34
4.5.4 Switch short/long .....	36
4.5.5 One button Dimming.....	39
4.5.6 One-button Shutter .....	43
4.5.7 LED Output .....	44
4.6. Logic.....	45
4.6.1 Logic object type switch .....	47
4.6.1 Logic object type scene .....	49

5 Index .....	50
5.1 Register of illustrations.....	50
5.2 List of tables.....	51
6 Attachment.....	52
6.1 Statutory requirements .....	52
6.2 Routine disposal .....	52
6.3 Assemblage.....	52
6.4 4-Bit Dim command.....	53
6.5 Datasheet .....	54

## 2 Overview

### 2.1 Overview devices

The manual refers to the following devices, which are in our assortment of universal interfaces. Actually we can offer you the following universal interfaces (Order Code respectively printed in bold type):

- **BE-04001.01** Input 4-fold, 4TE
  - 4 Inputs, for floating contacts & LEDs; 4 Logic blocks; LED Outputs parameterize able
- **BE-0200.01** Input 2-fold, 2TE
  - 2 Inputs, for floating contacts & LEDs; 4 Logic blocks; LED Outputs parameterize able

### 2.2 Exemplary circuit diagrams




Illustration 1: Exemplary circuit diagram BE0400.01- Model with 4 inputs




Illustration 2: Exemplary circuit diagram BE0200.01- Model with 2 inputs

## 2.2 Usage & areas of use

The universal interfaces are a special design of the binary inputs. They are used for the flush mounting behind push-buttons. Universal interfaces contain of the same functions like the binary input, but additional of a parameterize able LED output. The single Inputs and outputs passed out by individual connection cables.

## 2.4 Structure & Handling

The universal interfaces contain of individual connection cables for the each inputs and outputs. The single connection cables are color-marked (have a look at the assignment plan at the next page). The programming function can be activated by the programming button. The programming LED indicates the state, whether the programming function is switched on or off.




Illustration 3: Overview hardware module Universal Interface (here: BE-0400.01 for floating contacts, 4-fold)

The inputs of the 4-fold universal interface are occupied in this way:

Input A:	Black & Brown
Input B:	Red & Orange
Input C:	Yellow & Green
Input D:	Blue & White

→have a look at 2.2 Exemplar circuit diagram 1

The inputs of the 2-fold universal interface are occupied in this way:

Input A:	Black & Brown
Input B:	Red & Orange

→have a look at 2.2 Exemplar circuit diagram 2

## 2.5 Functions

The functionality is identical for every channel. The device contains of two or four channels based on the hardware design.

The designation of the channels is always in a consecutive alphabetic order.

There are three possible functionalities for each channel:

- **Disabled**

No function is set to the channel so that this channel does not contain of any communication objects.

- **Channels grouped**

If you select a pair of channel as “channels grouped”, you will be able to parameterize the pair of channels as dimming-function, shutter-function or switching- function.

- **Channels unique**

If you select a pair of channels as “channels unique”, you will be able to parameterize each channel for itself as switch, counter, scene, switch short/long, one button dimming or one button shutter.

There are additional 4 logic functions (and/or) containing of up to two additional input objects.

## 2.5.1 Overview functions

<b>General settings</b>	Debounce time	10-120ms, selectable in steps
	Time for keystroke long	0,1-30s, selectable in steps
	Limitation of telegrams	max. number of telegrams per 10s, can be parameterized freely
<b>Channels grouped</b>	Dimming function	brighter/darker function can be assigned to the channels freely
	Shutter function	up/down function can be assigned to the channels freely
	Switching function	off/on telegrams can be assigned to the channels freely
<b>Channels unique</b>	Switching function	<ul style="list-style-type: none"> <li>• switching function</li> <li>• toggle function</li> <li>• status function</li> <li>• time functions                             <ul style="list-style-type: none"> <li>○ switch on/off delay</li> </ul> </li> <li>• edge evaluation</li> <li>• forced settings</li> <li>• sending of byte-values</li> </ul>
	Scene function	<ul style="list-style-type: none"> <li>• memory function</li> <li>• selection of different scenes</li> </ul>
	Counter function	<ul style="list-style-type: none"> <li>• counting function</li> <li>• edge evaluation</li> <li>• counting steps can be chosen freely</li> </ul>
	Switch short/long	<ul style="list-style-type: none"> <li>• On-/Off-/toggle function</li> <li>• short/long independent parameterize able</li> </ul>
	One button dimming	<ul style="list-style-type: none"> <li>• steps of dimming</li> <li>• telegram repetition</li> </ul>
	One button shutter	<ul style="list-style-type: none"> <li>• shutter function with only one button</li> </ul>
	LED Output	<ul style="list-style-type: none"> <li>• LED Output normal/inverted</li> <li>• permanent-/flashing-function</li> </ul>
<b>Logic functions</b>	AND-function	<ul style="list-style-type: none"> <li>• switching function</li> <li>• scene function</li> <li>• inverting</li> </ul>
	OR-function	<ul style="list-style-type: none"> <li>• switching function</li> <li>• scene function</li> <li>• inverting</li> </ul>

Chart1: Functional overview universal interfaces



## 2.6 Settings at the ETS-Software

Selection at the product database:

Manufacturer: MDT Technologies

Product family: Binary Input

Product type: Universal Input

Medium Type: Twisted Pair (TP)

Product name: addicted to the used type, e.g.: BE-0400.01 Input 4-fold, 4TE

Order number: addicted to the used type, e.g.: BE-0400.01

## 2.7 Starting up

After wiring the allocation of the physical address and the parameterization of every channel follow:

- (1) Connect the interface with the bus, e.g. MDT USB interface
- (2) set bus power up
- (3) Press the programming button at the device (red programming LED lights)
- (4) Loading of the physical address out of the ETS-Software by using the interface (red LED goes out, as well this process was completed successful)
- (5) Loading of the application, with requested parameterization
- (6) Switch the power supply on
- (7) If the device is enabled you can test the requested functions (also possible by using the ETS-Software)

### 3 Communication objects

#### 3.1 Communication objects per channel

The communication objects appear for every channel in dependence of the respective parameterization. 10 numbers (0-9, 10-19,...) for communication objects are automatically assigned for every pair of channels. The numeration is consecutive, so the channel pair A/B can only have the numbers from 0 to 9, the same if they parameterized as grouped channels or unique channels. With every following channel pair the numbers of the objects increase by 10, even if a channel pair is disabled. If you choose a channel pair as unique, the channel, which is first in the alphabet, will become the first 5 numbers and the other one will become the following five numbers (e.g. channel A-->0-4 and channel B-->5-9). The numeration of the channels is always the same even if some channels are disabled.

Exceptions of this order are the communication objects for the LED-outputs. These communication objects have the numbers behind the logic blocks. Also here, the first number after the logic blocks is for the LED output of channel A, the second for the LED output of channel B and so on.

The communication objects are used for the assignment of the group addresses.

The following illustration shows the communication objects for the channels. Here, channel A/B are parameterized as grouped with a dual-surface dimming function. Channels C and D are adjusted as unique channels, so both channels have an individual function. Channel C is adjusted as switch and channel B as LED output:

Number	Name	Object Function	Description	Group Addresses	Leng...	C	R	W	T	U	Data Type	Priority
0	Input A / B	Dimming on/off			1 bit	C	R	-	T	-	1 bit DPT_Switch	Low
1	Input A / B	Dimming			4 bit	C	R	-	T	-	3 bit controlled DPT_Control_...	Low
10	Input C	Switch			1 bit	C	R	-	T	-	1 bit DPT_Switch	Low
11	Input C	Value for toggle			1 bit	C	-	W	T	U	1 bit DPT_Switch	Low
35	LED Channel D	LED switch			1 bit	C	R	W	T	U	1 bit DPT_Switch	Low

Illustration 4: Communication objects per channel

If a channel pair is selected as disabled, no objects will be shown. So there are no opportunities for programming this channel.

These are the available objects for each channel:

Nr.	Function	Usage	Data type	
0	Switch	edge control	DPT 1.001	Out, Read
0	Send forced setting	force control/switch	DPT 2.001	Out, Read
0	Shutters down/up	driving of shutters	DPT 1.008	Out, Read
0	Dimming on/off	toggling of the dimming lights	DPT 1.001	Out, Read
0	Switch on/off	two button switching	DPT 1.001	Out, Read
0	Reset counter	reset the counter value	DPT 1.001	In, Write
0	Send value	sends the parameterized value	DPT 5.001	Out, Read
0	push-button short	sends action for short keystroke	DPT 1.001	Out, Read
1	Value for toggle	edge control with toggle function	DPT 1.001	In, Write
1	Stop/Blinds open/close	driving of the blinds/ stopping movement of the shutters	DPT 1.009	Out, Read
1	Dimming	dimming	DPT 3.007	Out, Read
2	Scene	scene control	DPT 18.001	Out, Read
2	Value for change of direction	reversal of direction for shutters	DPT 1.001	Out, Read
2	push-button long	sends action for long keystroke	DPT 1.001	Out, Read
3	Counter	counting	DPT 12.001	Out, Read
4	Blocking object	blocks the related channel	DPT 1.001	In, Write
<b>+5</b>	<b>next channel</b>			
22/32	LED switch A	turn LED	DPT 1.001	Out, Read
+1	next LED output			

Chart 2: Communication objects per channel

## 3.2 Communication objects logic

There are communication objects for the logic function at every universal interface additional to the communication objects per channel. These objects can be parameterized and shown independent from the parameterization of the channels. The logic objects have the numbers from 20 at a 4-fold universal interface and the numbers from 10 at a 2-fold universal interface. The first logic block gets assigned the first three numbers, so at a 2-fold input from 10 to 12 and at a 4-fold input from 20 to 22. Every following block increases the numbers by 3.

The addressing can be made by using the communication objects for the logic analogous to the addressing by the channels.

The following communication objects for the logic can be shown:

Number	Name	Object Function
20	Logic input 1 A	Logic input 1 A
21	Logic input 1 B	Logic input 1 B
22	Logic output 1	Logic output 1

Illustration 5: communication objects logic

If a logic block is disabled, there will no communication objects be shown. Therefore no addressing is possible. Every binary input contains of 4 logic blocks for which the following objects can be shown:

Nr.	Function	Usage	Data type	
10/20	Logic input 1 A	Logic input	DPT 1.001	In, Write
11/21	Logic input 1 B	Logic input	DPT 1.001	In, Write
12/22	Logic output 1	Logic output	DPT 1.001	Out, Read
12/22	Logic output 1 scene	Logic output scene	DPT 18.001	Out, Read
<b>+3</b>	<b>next logic block</b>			

Chart 3: communication objects logic

### 3.3 Default settings of the communication objects

The following chart shows the default settings for the communication objects:

Default settings									
Nr.	Channel/Input	Function	Length	Priority	C	R	W	T	U
0	Input A	Switch	1 Bit	Low	X	X		X	
0	Input A	Shutter	1 Bit	Low	X	X		X	
0	Input A	Send value	1 Byte	Low	X	X		X	
0	Input A	Send forced setting	2 Bit	Low	X	X		X	
0	Input A	Reset counter	1 Bit	Low	X		X		X
0	Input A	Dimming on/off	1 Bit	Low	X	X		X	
0	Input A	push-button short	1 Bit	Low	X	X		X	
0	Input A	push-button short	1 Byte	Low	X	X		X	
0	Input A/B	Switch on/off	1 Bit	Low	X	X		X	
0	Input A/B	Dimming on/off	1 Bit	Low	X	X		X	
0	Input A/B	Shutter down/up	1 Bit	Low	X	X		X	
1	Input A	Value for toggle	1 Bit	Low	X	X		X	
1	Input A	Stop/Blinds open/close	1 Bit	Low	X	X		X	
1	Input A	Dimming	4 Bit	Low	X	X		X	
1	Input A/B	Dimming	4 Bit	Low	X	X		X	
1	Input A/B	Stop/Blinds open/close	1 Bit	Low	X	X		X	
2	Input A	Scene	1 Byte	Low	X	X		X	
2	Input A	Value for change of direction	1 Bit	Low	X		X	X	X
2	Input A	Value for toggle	1 Bit	Low	X		X	X	X
2	Input A	Push-button long	1 Bit	Low	X	X		X	
2	Input A	Push-button long	1 Bit	Low	X	X		X	
3	Input A	Counter	4 Byte	Low	X	X		X	
4	Input A	Blocking object	1 Bit	Low	X		X		X
+5	next input								
80/40	Logic input 1 A	Logic input 1 A	1 Bit	Low	X		X		X
81/41	Logic input 1 B	Logic input 1 B	1 Bit	Low	X		X		X
82/42	Logic output 1	Logic output 1	1 Bit	Low	X	X		X	
82/42	Logic output 1 scene	Logic output 1 scene	1 Byte	Low	X	X		X	
+3	next logic block								
22/32	LED channel A	LED switch	1 Bit	Low	X	X	X	X	X

Chart 4: Communication objects – default settings

You can see the default values for the communication objects from the upper chart. According to requirements the priority of the particular communication objects as well as the flags can be adjusted by the user. The flags allocate the function of the objects in the programming thereby stands C for communication, R for Read, W for write, T for transmit and U for update.

## 4 Reference ETS-Parameter

### 4.1 General Settings

The following parameters exist once and affect all channels:

General Settings	
Debounce Time [ms]	30 ms
Time for keystroke long [s]	0.8 s
startup timeout	1 s
Limitation of telegrams	Inactive
Behaviour at Bus power up	No read value for toggle

Illustration 6: General settings

The following chart shows the dynamic range for the general settings:

ETS-text	Dynamic range [default value]	comment
Debounce time	10..120 ms [10]	The inputs are debounced with this time
Time for keystroke long	0,1-30 sec [0.8 sec]	releases the time when the ETS recognizes a long keystroke
Limitation of telegrams	<ul style="list-style-type: none"> <li>▪ Inactive</li> <li>▪ Active</li> </ul>	activates/deactivates the limitation of telegrams
max quantity in 10 seconds	1-255 [15]	max number of telegrams per 10 seconds (appears only if the limitation of telegrams is activated)
Behavior at bus power up	<ul style="list-style-type: none"> <li>▪ No read value for toggle</li> <li>▪ Read value for toggle</li> </ul>	activates the reading of the value for toggle at bus power up

Chart 5: General settings

1. The setting option for the debounce time is for debouncing of the input signals from mechanical switches
2. The parameter "Time for keystroke long" allocates a static value to the universal interface from when a long keystroke is recognized. This parameter is important for functions, which have different functions for a long and a short keystroke.
3. The limitation of telegrams can achieve that the bus gets not overloaded. An overloading of the bus-system can cause long waiting periods, e.g. at pushing a button. If the limitation of telegrams is activated and more telegrams than allowed are send, the telegrams above the limitation will be send at the next time interval. Therefore an overload of the bus can be prevented.
4. The parameter "Behavior at bus power up" defines the behavior of the universal interface at a bus power return. The setting "Read value for toggle" effects that all communication objects "value for toggle" are read. So the Input knows the current status of the objects. If you choose the setting "no read value for toggle", the input will not know the current status of the actor. So the input assumes an unconfirmed value for the objects "value for toggle" and sends always a "0"-signal at the next operation. Only now the input knows the status of the actor and can send the right values. But if you choose the read of these values at a bus power up, the input will send immediately the right value for toggling.

## 4.2 Configuration

Setting of the functionality of the channels:

Illustration 7: Usage of the channels

ETS-text	Dynamic range [default value]	comment
Function Input A/B –[O/P]	<ul style="list-style-type: none"> <li>▪ <b>disabled</b></li> <li>▪ Channels grouped</li> <li>▪ Channels unique</li> </ul>	Operating mode of the channels

Chart 6: Parameter channel-configuration

There are 3 different operating modes for every channel( have a look at chart 6). The followig options to parameterize the channels are dependent to the choosen operating mode. If you disable the channel, there will be no options to parameterize this channel.



## 4.3 Identical parameter

### 4.3.1 Blocking object

As well for grouped channels as for unique channels the blocking object can be activated. At the unique channels one blocking object for every channel can be activated. For grouped channels, you can activate one blocking object for both channels. The communication object for a channel appears as soon as it is activated for a channel. At a 4-fold universal interface, there are so up to 4 blocking objects parameterize able. The corresponding channel of the blocking object is blocked by sending a logical 1. A blocked channel is not controllable as long as it is blocked. By sending a logical 0, the channel can be unblocked again.

Number	Name	Length	Usage
4	Blocking object	1 Bit	blocks the related channel by sending a logical 1

Chart 7: Communication object blocking object

## 4.4 Parameter Channels grouped

The chart shows the setting options for grouped channels:

ETS-text	Dynamic range [default value]	comment
Input A/B	<ul style="list-style-type: none"> <li>▪ <b>Dimming</b></li> <li>▪ Shutter</li> <li>▪ Switch</li> </ul>	Operating mode of the channel
Dimming function A/B	<ul style="list-style-type: none"> <li>▪ <b>Brighter/Darker</b></li> <li>▪ Darker/Brighter</li> </ul>	Defines which channel should dim up and which should dim down
Shutter function A/B	<ul style="list-style-type: none"> <li>▪ <b>Up/Down</b></li> <li>▪ Down/Up</li> </ul>	Defines which channel should drive the shutter a down and which up
Switch function A/B	<ul style="list-style-type: none"> <li>▪ <b>On/Off</b></li> <li>▪ Off/On</li> </ul>	Defines which channel should switch off and which on
Blocking Object	<ul style="list-style-type: none"> <li>▪ <b>Inactive</b></li> <li>▪ Active</li> </ul>	The blocking object can be displayed for every pair of channels

Chart 8: Parameter Channels grouped

By choosing channels as grouped, two channels become one common function. The grouped function is called dual surface, dual surface dimming, and dual surface shutter. In contrast to the single surface functions, one action can be performed independent form the other one. One input performs always one function. The assignment for the inputs can be made individually, so it is possible to configure which input should for example drive the shutters up and which down.

## 4.4.1 Dimming

The dual surface dimming function (channels grouped) is for controlling dimming actuators by start-stop dimming commands.

The following parameters are visible, when a pair of channels is chosen as dimming-function:

The screenshot shows a configuration window titled "Input A / B". Inside, there are three rows, each with a label on the left and a dropdown menu on the right. The first row is "Input A / B" with a dropdown showing "Dimming". The second row is "Dimming Function A / B" with a dropdown showing "Brighter/Darker". The third row is "Blocking Object" with a dropdown showing "Inactive".

Illustration 8: Parameter dual surface dimming

Number	Name	Length	Usage
0	Dimming on/off	1 Bit	Switching function of the dimming process; action for a short keystroke
1	Dimming	4 Bit	Dimming function; action for a long keystroke

Chart 9: Communication objects dual surface dimming

When a pair of channels is parameterized as dimming function, two objects are shown. One object reacts to a short keystroke, the switching object "Dimming on/off", and the other object reacts to a long keystroke, the dimming object "dimming".

It is possible to parameterize this function as brighter/darker or as darker/brighter. The first function belongs always to the first input. If you switch this parameter, the function will be switched automatically.

By choosing the dimming function (channel A/B) as brighter/darker, the function reacts in this way: A short keystroke at input A switches the lights on. The lights are switched off by a short keystroke at input B. A long keystroke dims the lights step by step until releasing the long keystroke. The lights are dimmed brighter at input A and darker at input B. The universal interface starts always with the last brightness level, before switching off.


The step size is set fixed to 100% at the dual surface dimming. It is a start-stop dimming. that means the lights are dimmed as long as you hold the button. After releasing the button a stop value is sent, which stops the dimming process. So you can dim the lights with only one keystroke from 0% to 100% or from 100% to 0%, by pushing the button long enough.

The chart shows the correlations between the dimming- and the switching-object:

Input	Function Brighter/Darker			Function Darker/Brighter	
	Input A	Input B		Input A	Input B
<b>Dimming function</b>	Brighter	Darker		Darker	Brighter
<b>Switching function</b>	On	Off		Off	On

Chart 10: Dimming function

The following diagram shows the dual surface dimming function:



## 4.4.2 Shutter

The dual surface shutter-function triggers shutter actuators, which can drive shutter and blinds. The following parameters are shown, when a pair of channel is adjusted as shutter function:

**Input A / B**

---

Input A / B Shutter ▼

Shutter Function A / B Up, Down ▼

Blocking Object Inactive ▼

Operation function Short=move / long=stop/blinds ▼

This setting can be apply for hardware starting from version 2.6 <- TIP

Illustration 9: dual surface shutter function

Number	Name	Length	Usage
0	Shutter Down/Up	1 Bit	Driving function for the shutters, action for a long keystroke
1	Stop/Blinds Open/Close	1 Bit	Stop/Adjustment of the blinds, action for a short keystroke

Chart 11: Communication objects dual surface shutter function

If you choose a pair of channels as shutter function, two communication objects will appear for this pair of channel. On the one hand the stop/blind adjustment object called "Stop/Blinds Open/Close", which responds to a short keystroke and on the other hand the Driving object called "Shutter Down/Up", which responds to a long keystroke.

The driving object is for moving the shutters up and down. The stop-/blind adjustment object is for the adjustment of the blinds and additional it stops a running movement of the shutter.

Every shutter actuator controls with a 0-signal the up-movement and with a 1-signal the down movement. So the universal interface sends these signals to the corresponding driving commands. From hardware version 2.6 (have a look at the print of the side of the device: RX.X), it is additional possible to switch the functions for a long and a short keystroke. So it can be chosen whether he shutter/blinds shall be driven via a long or a short keystroke. The Stop-/Blind adjustment object is adjusted by the other operating concept.

The Chart shows the correlations between the Stop-/Blind adjustment object and the driving object for the individual channels:

	Function Down/Up			Function Up/Down	
Input	Input A	Input B		Input A	Input B
Stop-/Blind adjustment object	Down	Up		Up	Down
Driving object	Stop/close blinds	Stop/open blinds		Stop/open blinds	Stop/close blinds

Chart 12: shutter function

## 4.4.3 Switch

The values for on and off can be assigned freely at the switching function for the grouped channels. If you adjust a pair of channel as switch, the following parameters will be shown:

**Input A / B**

Input A / B	Switch ▼
Switch function A / B	on / off ▼
Blocking Object	Inactive ▼

Illustration 10: dual surface switching function

Simple functions, like an alternating circuit, can be programmed easily by using the grouped switch function. The 1 bit communication object sends in dependence of the parameterization a 0- or a 1-signal for the first input and the inverted signal for the second channel. So you can chose which channel should switch off and which should switch on.

The following chart shows the corresponding communication object:

Number	Name	Length	Usage
0	Switch On/Off	1 Bit	Switching object for the dual surface switching function

Chart 13: Communication object dual surface switching function

## 4.5 Parameters channels unique

There are 7 different operating modes for the unique channels, which can be adjusted for each channel:

- Inactive
- Switch
- Scene
- Counter
- Switch short/long
- One button dimming
- One button shutter
- LED output

After the assignment of the operating mode the further parameterization can be done. If the channel is selected as inactive, no further parameterization will be possible.

### 4.5.1 Switch

The switching function is for switching the corresponding output on, off and toggling it. There is a multitude of sub-functions at the switching function, which enables the user to evaluate edges and integrate times to the switching process.

The following parameters are shown, when the channel is selected as switch:

The screenshot shows a configuration window titled "Input C". It contains three main sections: "Function", "Subfunction", and "Blocking Object".

- Function:** A dropdown menu with "Switch" selected.
- Subfunction:** A dropdown menu with "Toggle falling edge" selected. The menu is open, showing the following options:
  - Toggle falling edge (highlighted)
  - Switch rising edge
  - Toggle rising edge
  - Switch falling edge
  - Toggle falling edge
  - Send Status
  - Send value rising edge (1Byte / 2Bit)
  - Send value falling edge (1Byte / 2Bit)
  - Send value both edges (1Byte / 2Bit)
  - Send Status with on-delay
  - Send Status with off-delay
- Blocking Object:** A dropdown menu with "Inactive" selected.

Illustration 11: Parameter switch

Various sub-functions are available at a switching output. Most of these sub-functions contain also of further parameterization-options. The different sub-functions as well as their parameterization-options are described in the following segments:

## 4.5.1.1 Switch falling/rising edge


The following setting options are available, when the sub-function switch falling/rising edge was adjusted:

ETS-text	Dynamic range [default value]	comment
Value for rising/falling edge	<ul style="list-style-type: none"> <li>On</li> <li>Off</li> </ul>	switches on/off at a falling/rising edge

Chart 14: Parameter switch rising/falling edge

The sub-function “switch rising edge” or “switch falling edge” sends only a signal at the adjusted edge. You can parameterize whether a 0-signal or a 1-signal should be sent. There is no inverted signal at subsiding the edge. This function always sends only one adjusted signal.

The following diagram shows this sub-function for rising edges. As soon as the state changes from 0 to 1, the universal interface sends an On-pulse (=1-signal):



The following chart shows the corresponding communication object:


Number	Name	Length	Usage
0	Switch	1 Bit	Switching function, no differences between a long and a short keystroke

Chart 15: Communication object switch rising/falling edge

## 4.5.1.2 Toggle rising/falling edge

The sub-function “toggle rising edge” or “toggle falling edge” toggles at the adjusted edge. That means, the current value of the communication object is inverted at every switching process. By using this function an edge based alternating circuit can be realized.

The following diagram describes this sub-function. As soon as the state changes from 1 to 0, the binary input sends the inverted signal. The signal is send always as a short pulse:



The following chart shows the corresponding communication objects:

Number	Name	Length	Usage
0	Switch	1 Bit	Switching function; no differences between long and short keystroke
1	Value for toggle	1 Bit	status object, indicates the switching state of the channel

Chart 16: Communication objects toggle rising/falling edge



To be sure that the universal interface toggles at every switching process, you have to connect the status object of the binary input “Value for toggle” with the status object of the actuator. When the universal interface should work without an actuator, the object has to be connected to the switching object “switch”. The connection is important, because the universal interface cannot invert the signal, when it does not know its current state.

By undocking this communication object, you have more choices to program the input. So you can use the object “Value for toggle” for visualizations or additional functions and you will be more free in design your project.

So you have for example the option to visualize the switching process by connecting the status-object to a switching object of a LED or something else.

## 4.5.1.3 Send Status

By using the sub-function „Send status“ the input sends always the parameterized signal for the corresponding edge. The following window is shown for the sub-function “Send status”:

**Input C**

Function	<div>Switch ▾</div>
Subfunction	<div>Send Status ▾</div>
Value for rising edge	<div>On ▾</div>
Value for falling edge	<div>Off ▾</div>
Blocking Object	<div>Inactive ▾</div>
Behaviour at Bus power up	<div>send nothing ▾</div>
Send cyclic activ	<div>Off ▾</div>

Illustration 12: Sub-function send status

These settings are available:

ETS-text	Dynamic range [default value]	comment
Value for rising edge	<ul style="list-style-type: none"> <li>On</li> <li>Off</li> </ul>	switches on/off at a rising edge
Value for falling edge	<ul style="list-style-type: none"> <li>On</li> <li>Off</li> </ul>	switches on/off at a falling edge
Send cyclic	<ul style="list-style-type: none"> <li>Off</li> <li>On</li> </ul>	switches the cyclic sending on/off
Time interval for send cyclic	1-3000s [1]	Time between two sending processes
Behavior at bus power up	<ul style="list-style-type: none"> <li>send nothing</li> <li>send status</li> </ul>	defines the behavior at a bus power up

Chart 17: Parameter Send status

The corresponding communication object is shown at the following chart:

Number	Name	Length	Usage
0	Switch	1 Bit	Switching function; no differences between long and short keystroke


Chart 18: Communication object send status

The parameter “Value for rising edge” defines whether the channel should send an 1-signal (value: On) or a 0-signal (value: Off). If you want for example switch a channel of a switch actuator, you will have to choose different values for the rising and the falling edge. Otherwise the input sends the same signal twice, for example an On-signal.

The cyclic sending causes that the state of the input is sent periodically in certain parameterize able intervals. Then the input sends the parameterized value for the corresponding edge.

A common application for this parameter is for example the observation of windows, which are equipped with window-contacts. So a display can for example show whether all windows are closed or not. Furthermore an alarm device can operate with this function.

The following diagram describes this sub-function. In this example, the input sends an 1-signal for a falling edge and a 0-signal for a rising edge. Additional the diagram shows the connection with a switch actuator, which was parameterized with a normal switching function:



## 4.5.1.4 Send Value rising/falling/both edges

There are two further sub-functions at the sub-function Send Value. On the one hand you can send 1 Byte Values and on the other hand you can activate a forced setting (2 Bit). These functions can be parameterized according to your wishes.

The following illustration shows this parameter:

Illustration 13: Sub-function send value

After activating the sub function „Send value“, you have to choose which values should be sent. The setting options are shown at the chart:

ETS-text	Dynamic range [default value]	comment
Value (1 Byte)/ forced setting(2 Bit)	<ul style="list-style-type: none"> <li>• <b>1 Byte Value</b></li> <li>• 2 Bit Value(forced setting)</li> </ul>	Choice between 1 Byte- and 2 Bit-Value

Chart 19: Parameter send value

If you have activated the setting “1 Byte”, the following settings are possible:

ETS-text	Dynamic range [default value]	comment
Value for rising/falling edge	0-255 [0]	Assignment, which value should be send for the falling/rising edge

Chart 20: Parameter send value, 1 Byte object

The 1 Byte communication object can send any value in its dynamic range at both edges. The dynamic range is thereby from 0-255. Depending on parameterization the input sends the adjusted values for the rising or the falling edge or for both edges.

The following chart shows the according communication object:

Number	Name	Length	Usage
0	Send value	1 Byte	sends the parameterized value

Chart 21: Communication object Parameter Send value-1 Byte object

The setting option 2 Bit value (forced setting) has the following options to parameterize this function:

ETS-text	Dynamic range [default value]	comment
Send forced setting at rising/falling edge	<ul style="list-style-type: none"> <li>▪ <b>Forced setting not active</b></li> <li>▪ Forced setting off</li> <li>▪ Forced setting on</li> </ul>	Assignment, which forced setting should be send at which edge

Chart 22: Dynamic range send value-forced setting

The forced setting object allows for example to control the automatic brightness control of presence detectors.

The forced setting object can send 3 different states:

- **Forced setting not active (control=0; value=0)**  
The forced setting object has no influence on the receiver. For example at a presence detector, the automatic function (motion detector operation) would be switched on.
- **Forced setting off (control=1; value=0)**  
The forced setting object switches the receiver unconditionally off. For example a presence detector, would be switched permanent off. Detected motions have no influence on the output.
- **Forced setting on (control=1, value=1)**  
The forced setting object switches the receiver unconditionally on. For example a presence detector, would be switched permanent on. Detected motions have no influence on the output.

The according communication object is shown at the chart:

Number	Name	Length	Usage
0	Send forced setting	2 Bit	sends the adjusted forced setting

Chart 23: Communication object Send value-forced setting

## 4.5.1.5 Send value with on/off delay


The following setting options are available at the function “Send value with on/off delay”:

ETS-text	Dynamic range [default value]	comment
Delay time	0-60min [1s]	Adjustment of the delay time for the sending process

Chart 24: Parameter Send value with delay

The sub-function “Send value with on/off delay” allows that the binary input sends its value after a parameterized time. At the on-delay, the time starts when the associated input was switched on and at the off-delay, the time starts when the associated input was switched off. The universal interface sends always its current value at this function. If the value changes before the time ran out, the on-delay will expire. For example, when an input with a parameterized on-delay is switched off, before it was switched on, the input remains off.

The following diagram describes the sub-function „Send value with on-delay“:



You can see the adjusted settings, which were made in the ETS for this setting:

**Input D**

Function

Switch ▼

Subfunction

Send Status with on-delay ▼

Delay time

5 s ▼

Blocking Object

Inactive ▼

Illustration 14: Send value with on-delay

The following chart shows the communication object:

Number	Name	Length	Usage
0	Switch	1 Bit	Switching function; no differences between long and short keystroke

Chart 25: Communication object send value with delay

## 4.5.2 Scene

The scene function calls scenes, which are saved in actuators. Scene numbers in the universal interface and the actuators must be identical. It is possible to save scenes by a long keystroke if the saving function was activated.

The following illustration shows the setting options for this parameter:

The screenshot shows a window titled "Input D" with four settings:

- Function:** A dropdown menu with "Scene" selected.
- Subfunction:** A dropdown menu with "Save" selected.
- Scene Number:** A dropdown menu with "1" selected.
- Blocking Object:** A dropdown menu with "Inactive" selected.

Illustration 15: Parameter Scene

The following chart shows the dynamic range of this parameter:

Sub-function	Dynamic range [default value]	comment
Saving function	<ul style="list-style-type: none"> <li>No save</li> <li><b>Save</b></li> </ul>	Saving function is selected by a long keystroke
Scene number	1-64 [1]	Scene number must be identical with the one in the actuators
Blocking object	<ul style="list-style-type: none"> <li><b>Inactive</b></li> <li>Active</li> </ul>	have a look at 4.3.1 blocking object

Chart 26: sub-function scene

The chart shows the communication objects for this parameter:

Number	Name	Length	Usage
2	Scene	1 Byte	calls the depending scene

Chart 27: Communication object Parameter scene

The scene function calls scenes, which were stored in actuators. Scenes contain of parameterized states of several actuators, which can be called with only one keystroke by using the scene function. Additional to the call of scenes, scenes can be saved at the call of a universal interface by a long keystroke. When the saving function was activated, a long keystroke at the universal interface saves the current state of the actuators to the depending scene.



For calling a scene or saving a new value for the scene, you have to send the accordingly code to the relevant communication object for the scene:

Scene	Retrieve		Save	
	Hex.	Dez.	Hex.	Dez.
1	0x00	0	0x80	128
2	0x01	1	0x81	129
3	0x02	2	0x82	130
4	0x03	3	0x83	131
5	0x04	4	0x84	132
6	0x05	5	0x85	133
7	0x06	6	0x86	134
8	0x07	7	0x87	135
9	0x08	8	0x88	136
10	0x09	9	0x89	137
11	0x0A	10	0x8A	138
12	0x0B	11	0x8B	139
13	0x0C	12	0x8C	140
14	0x0D	13	0x8D	141
15	0x0E	14	0x8E	142
16	0x0F	15	0x8F	143
17	0x10	16	0x90	144
18	0x11	17	0x91	145
19	0x12	18	0x92	146
20	0x13	19	0x93	147
21	0x14	20	0x94	148
22	0x15	21	0x95	149
23	0x16	22	0x96	150
24	0x17	23	0x97	151
25	0x18	24	0x98	152
26	0x19	25	0x99	153
27	0x1A	26	0x9A	154
28	0x1B	27	0x9B	155
29	0x1C	28	0x9C	156
30	0x1D	29	0x9D	157
31	0x1E	30	0x9E	158
32	0x1F	31	0x9F	159

Chart 28: Calling and saving scenes

## 4.5.3 Counter

By using the counter function the number of switching processes can be counted. On doing this the universal interface can also make differences between the edges.

The following chart shows the sub-function of this parameter:

The screenshot shows a configuration window titled "Input C". It contains four rows of settings:

- Function:** A dropdown menu with "Counter" selected.
- Subfunction:** A dropdown menu with "Count rising and falling" selected.
- Sending difference:** A text input field with "5" and up/down arrow buttons.
- Blocking Object:** A dropdown menu with "Inactive" selected.

Illustration 16: Parameter counter

The sub-functions of this parameter are shown in the chart below:

Sub-function	Dynamic range [default value]	comment
Sub-function	<ul style="list-style-type: none"> <li>Count rising</li> <li>Count falling</li> <li><b>Count rising and falling</b></li> </ul>	at "count rising" only the rising edges will be counted at "count falling" only the falling edges will be counted
Sending difference	0-65535 [5]	the binary input sends the current value of the counter, when the sending difference is reached
Blocking object	<ul style="list-style-type: none"> <li><b>Inactive</b></li> <li>Active</li> </ul>	have a look at 4.3.1 blocking object

Chart 29: Sub-function counter

The chart shows the depending communication objects:


Number	Name	Length	Usage
0	Reset Counter	1 Bit	resets the counter
3	Counter	4 byte	outputs the current counter value

Chart 30: Communication object Parameter Counter

There is a setting which edge should be counted at the counter-function. If you select "Count rising and falling", the counter will count for toggling two switching processes. If only the rising or the falling edge should be counted, the counter will count only one switching process for toggling. The sending difference adjusts when the counter should send a value. When you have for example adjusted 10 as sending difference, the counter will count every switching process but send its value only at reaching 10.

The communication object "reset counter" sets the counter back to 0. This communication object reacts as well to a "0" as to a "1".

The following diagram shows the function of the counter with the setting "count rising and falling" and a sending difference of 5.




At this example, the counter sends only a value, when the counter value is a multiple of the sending difference. So the counter value is a continual rising value and the output value a periodic rising value.

As soon as the group address, in which the communication object "reset counter" is connected to, is addressed with a logical "0" or a logical "1", the counter value as well as the output value will be set back to 0.

## 4.5.4 Switch short/long

The parameter switch short/long can assign the input different switching processes for a long and a short keystroke.

The following illustration shows the sub-functions for this parameter:



The screenshot shows a configuration window titled "Input C". It contains four dropdown menus:

- Function:** Set to "Switch short/long".
- Value for keystroke short - Object 1:** Set to "On".
- Value for keystroke long - Object 2:** Set to "Toggle".
- Blocking Object:** Set to "Inactive".

Illustration 17: Parameter switch short/long

The sub-functions for this parameter are shown in the chart below:

Sub-function	Dynamic range [default value]	comment
Value for keystroke short - Object 1	<ul style="list-style-type: none"> <li>On</li> <li><b>Off</b></li> <li>Toggle</li> <li>Send value</li> <li>Nothing</li> </ul>	Action for a short keystroke
Value for keystroke long - Object 2	<ul style="list-style-type: none"> <li>On</li> <li>Off</li> <li>Toggle</li> <li>Send value</li> <li><b>Nothing</b></li> </ul>	Action for a long keystroke
Blocking object	<ul style="list-style-type: none"> <li><b>Inactive</b></li> <li>Active</li> </ul>	have a look at 4.3.1 blocking object

Chart 31: Sub-functions parameter switch short/long


The chart shows the associated communication objects:

Number	Name	Length	Usage
0	push-button short	1 Bit	Switching function short keystroke
2	push-button long	1 Bit	Switching function long keystroke

Chart 32: Communication object parameter switch short/long


The parameter “switch short/long” can control for example two channels of an actuator by using only one input. Furthermore you can switch a channel with a long keystroke on and with a short keystroke off. For both objects, a function can be set individually. Therefore the sub-functions on, off, toggle and nothing are available. Two communication objects are displayed, which can be connected in any way. By activating the sub-function “toggle” an additional communication object appears, called “value for toggling”. This object is a status object for the input and must be connected to the status-object of the actuator (have a look at: 4.5.1 Toggle)

The following diagram shows the behavior of this parameter. Both objects (push-button and push-button long) were set to toggle. The object for the long keystroke is connected to channel A of the switch actuator and the object for the short keystroke is connected to channel B:



In this example the binary input toggles Channel B with a short keystroke. The Channel A does not react to a short keystroke. This one reacts only at a long keystroke with toggling.

The following diagram shows a further application example for this parameter. In this example, the object for a long keystroke switches the channel A of a switch actuator on. A short keystroke switches the channel off. The three communication objects were connected in only one group address:



If the sub function “Send value” is selected, the following additional settings appear:

Sub-function	Dynamic range [default value]	comment
Value for keystroke short/long	Send value	chosen sub-function: Send value
Send value	<ul style="list-style-type: none"> <li>▪ <b>1 Byte-Value [0...255]</b></li> <li>▪ Scene number</li> </ul>	Selection of the value, which shall be sent
1 Byte-Value [0...255]	0-255 [0]	Selection of the byte value, which shall be sent if byte value is chosen
Scene number	1-64 [1]	Selection of the scene number, which shall be sent if scene number is chosen

Chart 33: Sub function Send value at switch short/long

Any value can be sent for the sub function „Send value“ at a short/long keystroke. As well scenes can be called as any byte value can be sent. So it is for example possible to call different scenes for a long and a short keystroke or sending absolute height/brightness commands.

## 4.5.5 One button Dimming

The dimming function for the unique channels, often called one surface dimming, performs the dimming process only by one channel.

The screenshot shows a configuration window titled 'Input C'. Inside, there are four rows of settings, each with a label on the left and a dropdown menu on the right:

- Function:** One Button Dimming
- Dimming steps:** 100%
- Repeat Telegram:** Yes
- Repetition time:** 2.0 s
- Blocking Object:** Inactive

Illustration 18: Parameter one surface dimming

The possible settings for this parameter are shown in the chart below:

Sub-function	Dynamic range [default value]	comment
Dimming steps	<ul style="list-style-type: none"> <li>100%</li> <li>50%</li> <li>25%</li> <li>12,5%</li> <li>3%</li> <li>1,5%</li> </ul>	The dimming steps specify how much should be dimmed by one dimming process.
Repeat telegrams	<ul style="list-style-type: none"> <li>No</li> <li>Yes</li> </ul>	switches the repeating of the dimming telegram on/off
Repetition time	<ul style="list-style-type: none"> <li>0,3s</li> <li>0,5s</li> <li>0,7s</li> <li>1,0s</li> <li>1,3s</li> <li>1,5s</li> <li>2,0s</li> <li>5,0s</li> </ul>	This parameter is only shown, when the repetition of telegrams was activated.
Blocking object	<ul style="list-style-type: none"> <li>Inactive</li> <li>Active</li> </ul>	have a look at 4.3.1 blocking object

Chart 34: Sub-functions one-surface dimming

The chart shows the communication objects for this parameter:

Number	Name	Length	Usage
0	Dimming on/off	1 Bit	Switching function for the dimming process; action for the short keystroke
1	Dimming	4 Bit	dimming function; action for a long keystroke
2	Value for toggle	1 Bit	status object, must be connected with the status function of the actuator for getting feedback of the current switching process

Chart 35: Communication objects one-surface dimming

The one-surface dimming performs the dimming process by using only one button. So it is possible to dim the lights by using only one button.

A long keystroke addresses the communication object "Dimming", which is for the dimming process. The short keystroke addresses the communication object "Dimming on/off", which is for the switching process.

Because of having only one button for performing the dimming process, the direction of the dimming process changes after every dimming process. That means, if you dimmed darker once before, the next time the lights will be dimmed brighter and the other way around.


The values for the dimming steps indicate how much the lights should be dimmed by along keystroke. It is here a start-stop dimming, which means you send as long a brighter or darker telegram as you push the button. As soon as you release the button, a stop telegram is sent, which stops the dimming process. So you can dim from 0% to 100% or from 100% to 0% if the dimming step is set to 100% by pushing the button long enough.

At a value of, for example 12,5%, 8 dimming processes are necessary to dim the lights by 100%.

When the telegram repetition is deactivated, you cannot dim the lights more than the value, which you have selected for the dimming steps, because the direction of dimming changes after every dimming process. You can additional adjust how long the binary input should wait between the single dimming steps by the repetition time.




The diagram shows the one-button dimming without repetition with an adjusted dimming step of 25%:



The lights can only be dimmed between the limits of 0% to 25% and 100% to 75%. This setting is, for example, useful if the lights should only be dimmed in a fixed range.

Consequently, you have to activate the repetition of telegrams if you want to dim the lights over the adjusted dimming step. By activating the repetition of telegrams, a new window is shown to adjust the repetition time. The repetition time indicates in which time intervals the brighter/darker telegram should be repeated. As long as the dimming function is activated by a long keystroke, the binary input sends the accordingly telegram.

The following diagram shows this function with an adjusted dimming step of 25% and a repetition time of 1s:



Now it is also possible to dim the lights by 100%, by using a dimming step less than 100%. The telegram is repeated as long as the maximum or the minimum is reached. Between the repetitions the universal interface waits the repetition time.

## 4.5.6 One-button Shutter

The shutter function for the unique channels, often called one-surface shutter, performs the shutter-function by using only one channel.

**Input D**

---

Function One Button Shutter ▼

Blocking Object Inactive ▼

Operation function Short=move / long=stop/blinds ▼

This setting can be apply for hardware starting from version 2.6 <- TIP

Illustration 19: Parameter one-surface shutter

The sub-functions for this parameter are shown in the chart below:

Sub-function	Dynamic range [default value]	comment
Blocking object	<ul style="list-style-type: none"> <li>▪ <b>Inactive</b></li> <li>▪ Active</li> </ul>	have a look at 4.3.1 blocking object

Chart 36: Sub-functions one-surface shutter

The chart shows the communication objects for this parameter:

Number	Name	Length	Usage
0	Shutter	1 Bit	Driving function of the shutter, action for a long keystroke
1	Blinds/Stop	1 Bit	Stop/ Adjustment of blinds; action for a short keystroke
2	Value for change of direction	1 Bit	Shows the last driving command

Chart 37: Communication objects one-surface dimming

The one-surface dimming is performed by using only one channel. The communication object "Shutter" is addressed by a long keystroke and performs the up- and down-movement of the shutter. The direction of movement depends to the last direction of movement. If the shutter were driven up at the last time, they will be driven down at the next time. So the direction of movement changes after every movement.

The communication object "Blinds/Stop" is addressed by a short keystroke. Addressing this object stops a running movement of the shutter. Furthermore it will adjust the blinds if a shutter function is selected for this channel. The direction of the adjustment changes also here after every movement in the same way like the up/down moving of the shutter.

From hardware version 2.6 (have a look at the print oft eh side of the device: R:X.X), it is possible to switch the functions for the short and the long keystroke. So it can be chosen whether a short or a long keystroke shall drive the shutter/blinds. The Stop-/ Adjustment object gets the other operating concept.

The object "Value for change of direction" serves as state object. It must be connected to the direction object of the actuator. So the interface sends always the complementary value as before.

## 4.5.7 LED Output

The following illustration shows the setting options for this parameter:

Illustration 20: Parameter LED Output

The following chart shows the dynamic range of this parameter;

Sub-function	Dynamic range [default value]	comment
LED state at objectvalue 0/1	<ul style="list-style-type: none"> <li>▪ <b>OFF/ON(normal)</b></li> <li>▪ ON/OFF(inverted)</li> </ul>	indicates the behaviour of the LED
LED state at ON	<ul style="list-style-type: none"> <li>▪ <b>permanent</b></li> <li>▪ blinking</li> </ul>	indicates the luminescent behaviour of the LED

Chart 38: Parameter LED Output

The LED function allows controlling LEDs at the output without any additional suppressor circuits. The universal interface delivers the necessary forward voltage as well as the contact current. Voltage of the output is set fixed to 2V DC and current to 1mA. Because the power supply of the LEDs is delivered by the bus, the output current is low. The values are designed for the use of "low current LEDs" to avoid an overload of the bus-system.

The behavior of the LED Output can be parameterized as well as the luminiscent behavior of the LEDs. The behavior of the output can be set as normal or as inverted.

By the luminescent behavior, you can set how the LED should shine. It is possible to let the LED shine permanent or periodically.

The communication object for the LED output is an 1-Bit object and can be controlled by a normal switching function. So, it is possible that the LED Output indicates the switching behaviour of another channel of the universal interface.

The chart shows the communication object for this parameter:

Numer	Name	Größe	Verwendung
22/32	LED Output A-B/D	1 Bit	switching of the LED at the output of the depending channel

Chart 39: communication object Parameter LED output

## 4.6. Logic

The universal interface contains of 4 individually switchable and parameterize able logic blocks. At the following page, the logic blocks can be activated and the general settings can be made:

**Settings for logic**

Behaviour at Bus power up	no read ext. logic objects ▼
Settings for logic 1	And ▼
objecttype 1	Switch ▼
Sending condition	not automatic ▼
Output inverted	No ▼
Settings for logic 2	Or ▼
objecttype 2	Scene ▼
Scene Number	2 ▼

Illustration 21: Activation logic blocks

The following parameter can be adjusted once and is valid for all of the 4 logic blocks:

Sub-function	Dynamic range [default value]	comment
Behavior at bus power up	<ul style="list-style-type: none"> <li>▪ <b>no read ext. logic objects</b></li> <li>▪ read ext. logic objects</li> </ul>	sub-function indicates whether the external logic objects should be read or not at a bus power up

Chart 40: Common Parameter logic blocks

If the read of the external logic at bus power up is activated, the status of all external logic objects will be read at a bus power up. So the logic operation is evaluated new. If this function is not active, the universal interface will hold the status before bus power outage.

The Chart shows the setting options for the logic blocks. The logic blocks can be assigned a logic function and an object type, the usage of this logic block:

Setting per logic [default value]	Dynamic range [default value]	comment
<ul style="list-style-type: none"> <li>disabled</li> <li>And</li> <li>Or</li> </ul>	<ul style="list-style-type: none"> <li>Switch</li> <li>Scene</li> </ul>	Every logic block can be adjusted as And- or as Or-function. Additional the object type (usage) can be adjusted for every block.

Chart 41: Dynamic range logic

The following chart shows the communication objects for the logic functions:

Number	Name	Length	Usage
80	Logic input 1A	1 Bit	Communication object for an external logic; is only displayed when an external logic was activated
81	Logic input 1B	1 Bit	the same like logic input 1A
82	Logic Output 1	1 Bit	Output logic for switch is activated (=1-signal) when the logic block is true
82	Logic Output 1 Scene	1 Byte	Output logic for scenes is activated (=1-signal) when the logic block is true

Chart 42: Communication objects logic

The communication objects for the other 3 possible logic blocks are the same like the first one. Three numbers are reserved for every logic block, so the next logic block starts at number 83.

As soon as a logic block is activated, a new sub-menu appears at the left selection list. In this menu can be set, which inputs should be connected to the logic block. Two external logic blocks can be activated additional. The external logic objects can be connected to communication objects of other devices by using the displayed communication objects "logic input 1 A&B".

**Logic 1**

Logical object 1 A (external)	<input type="text" value="normally active"/>
Logical object 1 B (external)	<input type="text" value="inverted active"/>
Input A	<input type="text" value="normally active"/>
Input B	<input type="text" value="inverted active"/>

Illustration 22: Setting logic

The read of the inputs (number depends to the device type) can be activated for every channel and two external objects. They can be read normal or inverted.

## 4.6.1 Logic object type switch

The chart shows the possible sub-functions for the logic sub-function switch:


Sub-function	Dynamic range [default value]	comment
Sending condition	<ul style="list-style-type: none"> <li>▪ <b>not automatic</b></li> <li>▪ change of input</li> <li>▪ change of output</li> </ul>	Adjustment indicates, when the state of the logic block should be sent
Output inverted	<ul style="list-style-type: none"> <li>▪ <b>No</b></li> <li>▪ Yes</li> </ul>	Adjustment indicates, whether the output should be inverted or not

Chart 43: Logic sub-function switch

The sending condition adjusts, when the binary input should send a signal on the bus. By adjusting the sending condition "change of input", the binary input sends a signal at every change of any input whether that causes a change of the logic operation or not. The setting "change of output" causes that the binary input sends only a signal when the logic changes its current status.

The sub-function Output inverted indicates whether the output signal should be issued inverted (that means reversed 1->0 and 0->1) or normal.

The following diagram shows the logic operation switch as an and-function. The logic reads in this example the channels A and B as well as an external logic object. The Output is inverted:



The logic function is only satisfied, when channel A and B as well as the external logic object have a 1-signal. The inversion of the output causes that the output is switched on, when the logic is not satisfied and switched off, when the logic is satisfied.



## 4.6.1 Logic object type scene

This logic function calls scenes, when the logic function is satisfied.

The chart shows the possible sub-functions for the logic operation scene:

Sub-function	Dynamic range [default value]	comment
Scene number	1-64 [2]	Scene number must be the same like the one you want to call with the logic-function

Chart 44: Logic sub-function scene

The logic function for the scenes works like a normal logic function. As soon as the logic function is satisfied, the communication object will send the adjusted scene-number. The communication object has the length of 1 Byte, so that it can be connected to other communication objects of scenes. All sub-functions, like in a normal logic function can be parameterized. So you can set the logic function as an AND- or an OR-function and connect all inputs of the binary input and additional 2 external logic objects to the logic function.

## 5 Index

### 5.1 Register of illustrations

Illustration 1: Exemplary circuit diagram BE0400.01	Page 4
Illustration 2: Exemplary circuit diagram BE0200.01	Page 5
Illustration 3: Overview hardware module Universal Interface	Page 6
Illustration 4: Communication objects per channel	Page 10
Illustration 5: communication objects logic	Page 12
Illustration 6: General settings	Page 14
Illustration 7: Usage of the channels	Page 16
Illustration 8: Parameter dual surface dimming	Page 18
Illustration 9: dual surface shutter function	Page 20
Illustration 10: dual surface switching function	Page 21
Illustration 11: Parameter switch	Page 22
Illustration 12: Sub-function send status	Page 26
Illustration 13: Sub-function send value	Page 28
Illustration 14: Send value with on-delay	Page 31
Illustration 15: Parameter Scene	Page 32
Illustration 16: Parameter counter	Page 34
Illustration 17: Parameter switch short/long	Page 36
Illustration 18: Parameter one surface dimming	Page 39
Illustration 19: Parameter one-surface shutter	Page 43
Illustration 20: Parameter LED Output	Page 44
Illustration 21: Activation logic blocks	Page 45
Illustration 22: Setting logic	Page 46

## 5.2 List of tables

Chart1: Functional overview universal interfaces	Page 8
Chart 2: Communication objects per channel	Page 12
Chart 3: communication objects logic	Page 11
Chart 4: Communication objects – default settings	Page 13
Chart 5: General settings	Page 14
Chart 6: Parameter channel-configuration	Page 16
Chart 7: Communication object blocking object	Page 17
Chart 8: Parameter Channels grouped	Page 17
Chart 9: Communication objects dual surface dimming	Page 18
Chart 10: Dimming function	Page 19
Chart 11: Communication objects dual surface shutter function	Page 20
Chart 12: shutter function	Page 20
Chart 13: Communication object dual surface switching function	Page 21
Chart 14: Parameter switch rising/falling edge	Page 23
Chart 15: Communication object switch rising/falling edge	Page 23
Chart 16: Communication objects toggle rising/falling edge	Page 24
Chart 17: Parameter Send status	Page 26
Chart 18: Communication object send status	Page 26
Chart 19: Parameter send value	Page 28
Chart 20: Parameter send value, 1 Byte object	Page 28
Chart 21: Communication object Parameter Send value-1 Byte object	Page 28
Chart 22: Dynamic range send value-forced setting	Page 29
Chart 23: Communication object Send value-forced setting	Page 29
Chart 24: Parameter Send value with delay	Page 30
Chart 25: Communication object send value with delay	Page 31
Chart 26: sub-function scene	Page 32
Chart 27: Communication object Parameter scene	Page 32
Chart 28: Calling and saving scenes	Page 33
Chart 29: Sub-function counter	Page 34
Chart 30: Communication object Parameter Counter	Page 34
Chart 31: Sub-functions parameter switch short/long	Page 36
Chart 32: Communication object parameter switch short/long	Page 36
Chart 33: Sub function Send value at switch short/long	Page 38
Chart 34: Sub-functions one-surface dimming	Page 39
Chart 35: Communication objects one-surface dimming	Page 40
Chart 36: Sub-functions one-surface shutter	Page 43
Chart 37: Communication objects one-surface dimming	Page 43
Chart 38: Parameter LED Output	Page 44
Chart 39: communication object Parameter LED output	Page 44
Chart 40: Common Parameter logic blocks	Page 45
Chart 41: Dynamic range logic	Page 46
Chart 42: Communication objects logic	Page 46
Chart 43: Logic sub-function switch	Page 47
Chart 44: Logic sub-function scene	Page 49

## 6 Attachment

### 6.1 Statutory requirements

The above-described devices must not be used with devices, which serve directly or indirectly the purpose of human, health- or lifesaving. Further the devices must not be used if their usage can occur danger for humans, animals or material assets.

Do not let the packaging lying around careless, plastic foil/ -bags etc. can be a dangerous toy for kids.

### 6.2 Routine disposal

Do not throw the waste equipment in the household rubbish. The device contains electrical devices, which must be disposed as electronic scrap. The casing contains of recyclable synthetic material.

### 6.3 Assemblage



#### **Risk for life of electrical power!**

All activities on the device should only be done by an electrical specialist. The county specific regulations and the applicable EIB-directives have to be observed.

## 6.4 4-Bit Dim command

The following chart describes the 4-Bit dimming command:

Decimal	Hexadecimal	Binaer	Dim command
0	0	0000	Stop
1	1	0001	100% Darker
2	2	0010	50% Darker
3	3	0011	25% Darker
4	4	0100	12,5% Darker
5	5	0101	6,25% Darker
6	6	0110	3,13% Darker
7	7	0111	1,56% Darker
8	8	1000	Stop
9	9	1001	100% Brighter
10	A	1010	50% Brighter
11	B	1011	25% Brighter
12	C	1100	12,5% Brighter
13	D	1101	6,25% Brighter
14	E	1110	3,13% Brighter
15	F	1111	1,56% Brighter

## MDT Universal Interface 2/4-fold, flush mounted

Version		
BE-02001.01	Universal Interface 2-fold	Flush mounted, for floating contacts, with LED output
BE-04001.01	Universal Interface 4-fold	Flush mounted, for floating contacts, with LED output

The MDT Universal Interface is to be inserted in a wiring box or behind a push button or switch. The inputs react depending on their programmed parameters and send a telegram on the bus. You can connect conventional push-buttons or auxiliary contacts (e.g. door and window contacts) to the device. The length of connection cables is 22cm. Each input can be set as a LED output and drive a low current LED.

**The MDT Universal Interface includes four integrated logical modules to implement logical operations and logical control. These logical modules interpret all the inputs plus two external objects. So you can easily create KNX/EIB telegrams which are required in daily practice (e.g. fault telegrams or „all windows closed“).**

Each input is parameterized individually via ETS3/4. The device provides extensive functions like switching of lighting, operation of blinds and shutters, counting of pulses, debounce time, contact type and telegram rate limitation. The command for rising and falling edge can be defined independently and with the block communication object each channel can be blocked or released. The logic module can release two telegrams after receiving a trigger signal from the inputs.


The MDT Universal Interface is a flush mounted device to be inserted in a wiring box or behind a push button or switch. It has to be installed in dry rooms.

For project design and commissioning of the MDT Universal Interface it is recommended to use the ETS3f/ETS4 or later. Please download the application software at [www.mdt.de/Downloads.html](http://www.mdt.de/Downloads.html)

BE-02001.01




BE-04001.01



- Production in Germany, certified according to ISO 9001
- Modern design
- Fully compatible to all KNX/EIB devices
- To connect conventional push-buttons or window/auxiliary contacts
- **4 integrated logical modules**
- Telegram rate limitation
- NO or NC contact operation, programmable length of button push
- Operation of blinds and shutters, 1 and 2 button operation
- Forced setting function for each output
- Operation with short/long button push and 2 objects
- Counting of pulses
- Cyclical sending of contact state programmable
- Each output can be set as 1,5mA output for low current LED
- Flush mounted (length of connection cables: 22cm)
- Dimensions (W x H x D): 41mm x 41mm x 12mm
- Integrated bus coupling unit
- 3 years warranty

Electrical Data	BE-04000.01	BE-02000.01
Number of Inputs	4	2
Permitted wire gauge		
KNX busconnection terminal	0,8mm Ø, solid core	0,8mm Ø, solid core
Power Supply	via KNX bus	via KNX bus
Power consumption	<0,3W	<0,3W
Permitted input cable length	5m	5m
Operation temperature range	0 to + 45°C	0 to + 45°C
Enclosure	IP 20	IP 20
Dimensions UP (W x H x D)	41mm x 41mm x 12mm	41mm x 41mm x 12mm

Exemplary circuit diagram BE-02001.01



Exemplary circuit diagram BE-04001.01

