



Declaration of Conformity

| For the following equipment | nt: | | | |
|--|-------------------------------|-------------------------------|-------------------|---|
| Product Name: Switching | Power Supply | | | |
| Model Designation: HDR-1 | 150-X(X=12,15,24,48) | | | |
| is herewith confirmed to capplied: ROHS Directive (2011 Low Voltage Directive (EN62368-1:2014 / A11:20 | /65/EU) (2014/35/EU): | C | CB certificate No | |
| EN61558-1:2005+A1 / EN61558-2-16:2009+A1 | | TUV certificate No: R50421082 | | |
| Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad | terference) | 2014/30/EU): | | Class B |
| Harmonic current | EN61000-3-2:2014 | | | |
| Voltage flicker | EN61000-3-3:2013 | | | |
| EMS (Electro-Magnetic S | Susceptibility) | | | _ |
| EN55024:2010+A1:2015 | | | | |
| ESD air | EN61000-4-2:2009 | | Level 4 | 15KV |
| ESD contact | EN61000-4-2: 2009 | | Level 4 | 8KV |
| RF field susceptibility | EN61000-4-3:2006+ | A1:2008+A2:2010 | Level 3 | 10V/m |
| EFT bursts | EN61000-4-4:2012 | | Level 3 | 2KV/5KHz |
| Surge susceptibility | EN61000-4-5:2014 | | Level 4 | 2KV/Line-Line |
| Surge susceptibility | EN61000-4-5:2014 | | Level 4 | 4KV/Line-Earth |
| Conducted susceptibility | EN61000-4-6:2014 | | Level 3 | 10V |
| Magnetic field immunity | EN61000-4-8:2010 | | Level 4 | 30A/m |
| Voltage dip, interruption | EN61000-4-11:2004 | >95% dip 0.5 periods | 30% dip 25 period | ls >95% interruptions 250 periods |
| Note: The power supply is considered be affected by the complete in again. For guidance on how to perform | nstallation, the final equipr | ment manufacturers mu | st re-qualify EMC | uipment. Since EMC performance will Directive on the complete installation File). |
| This Declaration is effective fr | om serial number EB8xxx | xxxx | | |
| Person responsible for ma | rking this declaration: | | | |
| MEAN WELL Enterprises | Co., Ltd. | | | |
| (Manufacturer Name) No.28, Wuquan 3rd Rd., V | /ugu Dist., New Taipei | City 24891, Taiwan | | |
| (Manufacturer Address) | | 1 | | (1) |
| Johnny Huang/Manager, Certification Center: (Signature) Alex Tsai/Director, Marketing Department: (Name / Position) (Signature) | | | | |
| Taiwan (Place) | Nov. 19th, | 2018 | | |