



Data sheet

KNX IP BAOS 777

(Art. # 5193)

Interface and ObjectServer between LAN and KNX Bus





Application area

The KNX IP BAOS 777 is used as an interface to connect to KNX both on the telegram level (KNXnet/IP Tunneling) and on datapoint level (KNX Application Layer) with up to 2000 communication objects (when using the generic product database). BAOS stands for "Bus Access and ObjectServer". The connection is made through LAN (IP).



Typical Application

The ObjectServer can be accessed through TCP/IP or UDP/IP via the KNX Binary Protocol V2.1. Alternatively, the ObjectServer can be accessed through Representational State Transfer (RESTful) services and Web Services based on Java Script Object Notation (JSON). The device is compatible with ETS 4.2 or higher.

Technical Specification

Electrical safety

Protection (acc. EN 60529): IP 20

CE marking according to

- EMC directive 2014 / 30 / EU
- RoHS directive 2011 / 65 / EU
- EN 50491-3: 2009, EN 50491-5-1: 2010
 EN 50491-5-2: 2010, EN 50491-5-3: 2010
- EN 61000-6-2: 2005

EN 61000-6-3: 2007 + A1: 2011

EN 50581: 2012

Environmental requirements

- Ambient temp. operating: 5 ... + 45 °C
- Ambient temp. non-op.: 25 ... + 70 °C
- Rel. humidity (non-condensing): 5 % ... 93 %

Mechanical data

- Housing: plastic (PC)
- DIN rail mounted device, width: 2 units (36 mm)
- Weight: approx. 90 g

Controls and indicators

- OLED display with 4 buttons
- Programming LED (RD)

Ethernet

- 100 Mbit/s
- Supported internet protocols ARP, ICMP, IGMP, UDP/IP, TCP/IP and DHCP
- Up to 8 KNXnet/IP Tunneling connections simultaneously
- Up to 10 BAOS connections simultaneously.

KNX

- Medium TP
- Interface protocol: cEMI
- Max. APDU length: 55
- Object Server: BAOS V2
- Device model: System B

Power Supply

- External supply 12-30 V= alternative: Power over Ethernet PoE
- Power consumption: < 1,5 W

Connectors

- Bus connector for KNX (RD / BK)
- Connector for external power supply (YE / WH)
- LAN RJ-45 socket

Installation Instructions

 The device may be used for permanent interior installations in dry locations, within distribution boards or small casings with DIN rail.



WARNING

- The device must be mounted and commissioned by an authorized electrician.
- The prevailing safety rules must be heeded.
- The device must not be opened.
- For planning and construction of electric installations, the relevant guidelines, regulations and standards of the respective country are to be considered.



ETS4/5 Database www.weinzierl.de/en/products/777/ets4 Manual www.weinzierl.de/en/products/777/manual

CE Declaration

www.weinzierl.de/en/products/777/ce-declaration

www.weinzierl.de info@weinzierl.de 2019/03/05

Germany